



Water Pipe Markers

Product Images



Short Description

Water Pipe Markers

Description

Water Pipe Markers successfully identify the contents and flow of pipes allowing workers to safely trace process problems and get production back in line faster.

- Pipe Markers are to be located adjacent to valves, junctions, bulkheads, service appliances & wall penetrations.
- Markers must be spaced no more than 8m apart with the exception of long, uninterrupted straight runs of external services where spacing shall not exceed 50metres.
- Comes in a packet of 10.
- Use in conjunction with our Supplementary Safety Markers (sold separately) for instances where additional information about the contents of a pipe is required.
- Bronson Safety Pipe Markers comply to AS 1345-1995 & AS 2700 1996.

Additional Information

Label Type	Pipe & Valve Marking
------------	----------------------

Product Options

Label Legend:	Boiler Feed Water
	Chilled Water
	Circulating Water
	Cold Water
	Cold Water Flow
	Cold Water Return
	Cooling Water
	Distilled Water
	Domestic Cold
	Domestic Hot Water
	Domestic Water
	Drain Water
	Drinking Water
	Feed Water
	Fresh Water
	Heating Water
	Hot Water
	Hot Water Flow
	Hot Water Return
	Non-Potable Water
	Overflow
	Potable Water
	Storm Water
	Treated Water
	Waste Water
Label Size:	30mm x 380mm
	50mm x 400mm

